

November 28, 2018

VIA E-MAIL TO: Denton.Miller@ontario.ca

Denton Miller
Senior Noise Engineer
Ministry of the Environment, Conservation and Parks
135 St. Clair Ave W
Toronto, ON M4V 1P5

Re: Grand Bend Wind Farm REA #5186-9HBJXR, Information Request
Grand Bend Wind Farm

Dear Mr. Miller,

The following points address the email sent to Mr. Jim Mulvale, on November 22, 2018, requesting supplemental information to support the Immission Audits of the Grand Bend Wind Farm.

- (1) Two letters confirming the turbines were parked during ambient (off) conditions in both the spring and fall measurement campaigns can be found in Appendix A.
- (2) The Environmental Noise Impact Assessment Report included 48 proposed wind turbine generators for the site. Eight of the proposed turbines were alternates and only 40 turbines were constructed. Wind turbines T4, T10, T15, T24, T28, T36, T40 and T47 were not installed. The updated sound level predictions include only the 40 constructed turbines, which results in lower predicted sound levels at most receptor locations.

The discrepancy in the predicted sound level at receptor R258 between the Spring and Fall Immission Audit Reports is due to a typographical error made in the Fall Immission Report, dated March 10, 2017. The correct predicted sound level of 38.4 dBA for R258 appears in the Spring Immission Report, dated September 26, 2018.

- (3) As requested, the Cadna file will be provided to the MECP.
- (4) The anemometers follow a 24 month calibration schedule. Both anemometers were calibrated again in February of 2017. The new calibration certificates for the anemometers can be found in Appendix B.

(5) The distance correction was determined using the following formula:

$$\text{distance correction} = 20 * \log\left(\frac{D_{\text{monitor}}}{D_{\text{receptor}}}\right)$$

The mean distance correction for the three closest turbines, T18 (0.4 dBA), T21 (0.9 dBA) and T22 (1.4 dBA) was used to yield a distance correction of 0.9 dBA. The distance correction is independent of the predicted sound levels found in Table 1.

We trust this information is helpful. If you have any questions or concerns, please do not hesitate to contact us.

Yours truly,
Howe Gastmeier Chapnik Limited



Nathan Gara, C.E.T.



Ian R. Bonsma, PEng



ACOUSTICS



NOISE



VIBRATION

APPENDIX A



ACOUSTICS



NOISE



VIBRATION



November 26, 2018

SUBJECT : Statement of Operation - Fall Immissions Audit - Grand Bend Wind Farm

To whom it may concern,

This letter is to confirm that the wind turbine generators at the Grand Bend Wind Farm were operating normally during the post-construction acoustics audit, conducted between October 25, 2016 and February 1, 2017. Additionally, this letter confirms that the relevant turbines were parked for ambient (OFF) condition measurements

Yours Truly,

A handwritten signature in black ink, appearing to read 'B. Becking', with a long horizontal flourish extending to the right.

Ben Becking,

Site Supervisor
Grand Bend Wind Limited Partnership
2 Parkside Ave.
Zurich, Ontario
N0M 2T0



November 26, 2018

SUBJECT : Statement of Operation - Spring Immissions Audit - Grand Bend Wind Farm

To whom it may concern,

This letter is to confirm that the wind turbine generators at the Grand Bend Wind Farm were operating normally during the post-construction acoustics audit, conducted between March 9, 2017 and July 21, 2017. Additionally, this letter confirms that the relevant turbines were parked for ambient (OFF) condition measurements.

Yours Truly,

A handwritten signature in black ink, appearing to be 'BB' followed by a long horizontal flourish.

Ben Becking,

Site Supervisor
Grand Bend Wind Limited Partnership
2 Parkside Ave.
Zurich, Ontario
N0M 2T0

APPENDIX B



ACOUSTICS



NOISE



VIBRATION



SOH Wind Engineering LLC

141 Leroy Road · Williston, VT 05495 · USA
Tel 802.316.4368 · Fax 802.735.9106 · www.sohwind.com

NRG8

CERTIFICATE FOR CALIBRATION OF CUP ANEMOMETER

76

Certificate number: 17.US1.01491

Date of issue: February 06, 2017

Type: RNRG 40C Anemometer

Serial number: 179500244813

Manufacturer: Renewable NRG Systems Inc, 110 Riggs Road, Hinesburg, VT 05461, USA

Client: HGC Engineering, 2000 Argentinia Road, Plaza One, Suite 203, Mississauga, ON L5N 1P7, Canada

Anemometer received: February 03, 2017

Anemometer calibrated: February 03, 2017

Calibrated by: MEJ

Procedure: MEASNET, IEC 61400-12-1:2005(E) Annex F

Certificate prepared by: EJF

Approved by: Calibration engineer, EJF

Calibration equation obtained: v [m/s] = 0.75963 · f [Hz] + 0.36998

Eric Jeffrey

Standard uncertainty, slope: 0.00188

Standard uncertainty, offset: 0.05239

Covariance: -0.0000258 (m/s)²/Hz



Coefficient of correlation: ρ = 0.999981

Absolute maximum deviation: -0.050 m/s at 3.971 m/s

Barometric pressure: 1005.2 hPa

Relative humidity: 13.1%

Succession	Velocity pressure, q [Pa]	Temperature in wind tunnel [°C]	Temperature in d.p. box [°C]	Wind velocity, v [m/s]	Frequency, f [Hz]	Deviation, d [m/s]	Uncertainty u_c (k=2) [m/s]
2	9.29	23.6	26.2	3.971	4.8065	-0.050	0.025
4	14.68	23.6	26.2	4.991	6.0955	-0.009	0.026
6	21.15	23.6	26.2	5.991	7.3783	0.017	0.027
8	28.76	23.6	26.2	6.986	8.7045	0.004	0.030
10	37.64	23.6	26.2	7.992	10.0257	0.006	0.033
12	47.76	23.6	26.2	9.003	11.3304	0.026	0.036
13-last	58.77	23.6	26.2	9.987	12.5955	0.049	0.038
11	71.00	23.6	26.2	10.977	13.9650	-0.001	0.041
9	84.65	23.6	26.2	11.987	15.2722	0.016	0.045
7	99.35	23.6	26.2	12.987	16.6232	-0.011	0.048
5	115.18	23.6	26.2	13.984	17.9385	-0.013	0.051
3	131.29	23.6	26.2	14.929	19.1810	-0.011	0.054
1-first	149.62	23.6	26.2	15.937	20.5190	-0.020	0.057





SOH Wind Engineering LLC

141 Leroy Road · Williston, VT 05495 · USA
Tel 802.316.4368 · Fax 802.735.9106 · www.sohwind.com

NRG 9

CERTIFICATE FOR CALIBRATION OF CUP ANEMOMETER

NRG
Feb 9, 2017

Certificate number: 17.US1.01493

Date of issue: February 06, 2017

Type: RNRG 40C Anemometer

Serial number: 179500244824

Manufacturer: Renewable NRG Systems Inc, 110 Riggs Road, Hinesburg, VT 05461, USA

Client: HGC Engineering, 2000 Argentia Road, Plaza One, Suite 203, Mississauga, ON L5N 1P7, Canada

Anemometer received: February 03, 2017

Anemometer calibrated: February 03, 2017

Calibrated by: MEJ

Procedure: MEASNET, IEC 61400-12-1:2005(E) Annex F

Certificate prepared by: EJJ

Approved by: Calibration engineer, EJJ

Calibration equation obtained: $v [m/s] = 0.76309 \cdot f [Hz] + 0.35260$

Eric Jeffrey

Standard uncertainty, slope: 0.00196

Standard uncertainty, offset: 0.05745

Covariance: -0.0000283 (m/s)²/Hz

Coefficient of correlation: $\rho = 0.999979$

Absolute maximum deviation: 0.058 m/s at 10.986 m/s

Barometric pressure: 1004.9 hPa

Relative humidity: 13.1%

Succession	Velocity pressure, q, [Pa]	Temperature in wind tunnel [°C]	d.p. box [°C]	Wind velocity, v, [m/s]	Frequency, f, [Hz]	Deviation, d, [m/s]	Uncertainty u _c (k=2) [m/s]
2	9.26	23.6	26.2	3.965	4.7834	-0.037	0.025
4	14.67	23.7	26.2	4.991	6.0955	-0.013	0.026
6	21.07	23.7	26.2	5.980	7.3582	0.013	0.027
8	28.71	23.6	26.2	6.981	8.6820	0.003	0.030
10	37.55	23.6	26.2	7.984	9.9937	0.005	0.033
12	47.65	23.6	26.2	8.994	11.3084	0.012	0.036
13-last	58.71	23.6	26.2	9.984	12.5942	0.021	0.038
11	71.09	23.6	26.2	10.986	13.8583	0.058	0.041
9	84.60	23.6	26.2	11.985	15.2349	0.007	0.045
7	99.19	23.6	26.2	12.978	16.5833	-0.029	0.048
5	114.93	23.6	26.2	13.971	17.8834	-0.029	0.051
3	131.68	23.6	26.2	14.954	19.1298	0.004	0.054
1-first	149.86	23.6	26.2	15.952	20.4625	-0.015	0.057

